

RFP - MANAGEMENT OF SELF SERVICE FUEL FACILITY
FELTS FIELD AIRPORT

QUESTIONS AND ANSWERS

Q: Are the Underground Storage Tanks and Piping System currently in compliance? With EPA/Dept of Ecology and ATA Spec 103?

A: Department of Ecology records indicate tanks are in compliance.

Q. Will the Airport certify and correct any compliance deficiencies before the lessee takes possession?

A. The Airport is unaware of any compliance deficiencies.

Q. What Overfill Prevention System is installed?

A. Unknown

Q. Is the Credit Card Processing System Compliant with Credit Card Processing Rules & Regulations?

A. Unknown

Q. When was the last soil sample done?

A. March 11, 2010. There was no indication of any contamination. We are waiting for the analytical data.

Q. When were the tanks last leak checked?

A. Airport has scheduled tank tightness testing to be done Monday, March 15, 2010.

Q. Is there a tank monitoring system in place? If so what type and what manufacture?

A. Unknown

Q. When were the tanks installed in the Ground?

A. 1986

Q. What are the age of the tanks?

A. Unknown

Q. Is there Cathodic Protection for the tanks and system?

A. Yes